

## Facilities Update: Tuesday February 8, 2022

### ES Flooring

- Cove base completed - phase 1 100% complete
- 5 coats semi-gloss were added to floors for resiliency/cleaning
- Phase 2 will commence July 2022

### MS Roof

- 2 bids received
- Initial meeting with 3<sup>rd</sup> vendor complete, Vision 3 Architects
  - o Site walkthrough scheduled for 02/08
- Bid analysis to be completed once 3<sup>rd</sup> bid received

### Staff Laptops

- Devices were distributed on 1/12
- Paraprofessionals also received a device (iPad's)
- Project complete

### ES Broken Seals/Window Coverings

- Project resumed 1/14 and additional windows were installed
- Approx 6-8 windows remain – will be completed over February break
- Window coverings complete

### ES Gym Roof

- Star Manufacturing and DAR completed on-site inspection the week of 1/17
- Issue identified as faulty seaming of room
- A “cap” is being manufactured to line the seam (has been done at other sites to solve similar issue)
- Install needs to occur when temperatures exceed 50 degrees

### ES Lobby Rot/Corrosion

- Final remaining facilities capital project for FY22
- Vendors being contacted – anticipated completion over spring break

### ES 10gb & Firewall

- New 10gb circuit being installed/going live in ES
- Will give both schools failover and redundancy
- New firewalls purchased and will be installed to compliment new 10gb