

2022 Facilities Report

New Projects

Theatre Room Repairs and Requirements Per Fire Marshall

- 1 Prepare As-Built drawings for existing Stage Area to Building and Safety and Fire for Approval
Prepare As-Built drawings for Sound Boothe Area as well for Approval
Add Sprinklers under Sound Boothe area per Fire Dept requirements

Kitchen Cooking Area

- 1 New Equipment has been installed need to relocate fire Suppression nozzles overhead add new drops
- 2 Working with Fire Suppression contractor for plans and Permit cost for repairs

Additional Repairs for Fire inspection

Repair all holes in walls

Add fire Sealant in any penetrations

Repair all Broken ceiling Tiles

Remove all Extension cords in Classrooms

Spray all Hanging Curtains with Fire Retardant Spray per Fire Marshall

Daily Maintenance and Repairs

Pricing for Parking Lot Restripe and Seal Requires Approval

Portables Remove all Carpet and install new Flooring Requires Approval

Projects completed

Big Top New Cement Floor

Classrooms all Carpet removed and Floors Polished Cement For Sanitation

Annual Fire Alarm Report complete